

To

The Principal,
BBD Dav Public Sen.Sen.School,
Chanarthal khurd, F.G.S

Ref No. 301

Dated- 03.04.2025

Sub:- Regarding Test Report of Water Sample.


Ref:- Your office letter/SRF No. 150/24-25 Dated 25.03.25

Sir/Madam,

With reference to the subject cited above, it is intimated that the water sample submitted by your school has been tested by the District Water Testing Laboratory, Fatehgarh Sahib.

The Quality Parameters of the water sample are within permissible limits as per the reports received from the Quality Manager. The water sample test report is attached with this letter for your kind reference and necessary action please.

**Encl: Water Sample
Test Reports**


Sub Divisional Engineer,
Water Supply and Sanitation Sub Div.
No-1, Fatehgarh Sahib

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com



To,

Principal
BBD Dav Public Sen. Se. School, Chanarthal Khurd, FGS

No.: DWTLFGS/2425/00625 Dated : 31/03/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 150/24-25 Dated: 25/03/2025

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 26/03/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Fatehgarh Sahib

D/A : Test Report

Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com

Receiving Diary No:

Date 04/04/25

Signature



TC-12711

TEST REPORT

Name & Address of Customer : Principal BBD Dav Public Sen. Se. School, Chanarthal Khurd, FGS		Customer Reference No.	No : 150/24-25 Dated : 25/03/2025
		Sample Submitted by	
		Date of Sample Receipt	26/03/2025
		Analysis Starting Date	26/03/2025
		Analysis completion Date	27/03/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC127112500000202F	Sample Type :	Water
Test Report No.:	DWTLFGS/2425/00625	Date of Issue :	31/03/2025
Registration no.:	DWTLFGS/REG2425/01807	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	500 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	BBD Dav Public Sen. Se. School, Chanarthal Khurd, FGS / NA
Village :	Chanarthal Khurd	Habitation :	Chanarthal Khurd
Block:	Sirhind	District :	Fatehgarh Sahib
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.88	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	380	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	244	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	252	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	38	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	38	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	38	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Brij Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com



TC-12711

TEST REPORT

Name & Address of Customer : Principal BBD Dav Public Sen. Se. School, Chanarthal Khurd, FGS		Customer Reference No.	No : 150/24-25 Dated : 25/03/2025
		Sample Submitted by	
		Date of Sample Receipt	26/03/2025
		Analysis Starting Date	27/03/2025
		Analysis completion Date	28/03/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC127112500000202F	Sample Type :	Water
Test Report No.:	DWTLFGS/2425/00625	Date of Issue :	31/03/2025
Registration no.:	DWTLFGS/REG2425/01806	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	BBD Dav Public Sen. Se. School, Chanarthal Khurd, FGS / NA
Village :	Chanarthal Khurd	Habitation :	Chanarthal Khurd
Block:	Sirhind	District :	Fatehgarh Sahib
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.09	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	120	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	48	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	52	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	5	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	10	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Brij Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib

End of the Test Report